

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Partial	Friday, March 10, 2017

Partial Correction
1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 1ST FLOOR LOCATIONS: EAST WALL OF ELECT 3-161; OK TO 4' TOP-OUT WALLS; AREA "A"; AREA "C" COMPLETE EXCEPT C160; B153; D161; B209; B258A;

Partial Correction
2 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 2ND FLOOR LOCATIONS: A218; C271; AREA "A"; AREA "C" N OF STAIR; BETWEEN COMMONS A-C EXCEPT 202,3,6,9,18.

Comments: