

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20162134, Public Works Infrastructure Permit - Commercial
HT SOLUTIONS

Address: 1440 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-ESC - (Vegetation/Ground Cover) Informational	Brice Lawson	Partial	Friday, March 10, 2017
1	Brice Lawson 01/26/2017 9:07 AM		
	On 1/15/16 most of the site was hydromulched. The area north of the building where the ground has been graded has not been hydromulched.		
Informational			
2	Brice Lawson 03/03/2017 11:19 AM		
	On 3/2/17 I met with Kenny Westberg with Advanced Erosion Solutions LLC 913-390-8000 to go over the plans to add ESC devices and seeding to this site.		
Informational			
3	Brice Lawson 03/10/2017 3:53 PM		
	The site has been seeded. The seeded areas were covered with hydro mulch and flock lock (tackifier). ESC straw mats were installed on the inner slopes of the detention basin and part of the outer slope of the east berm. Straw waddles were installed in the swale next to the east berm and at the areas where it appeared that the water leaving the site would drain.		

Comments: