

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162811, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, March 13, 2017

Partial Correction
1 Misc 1

NEW DOOR 120B -- OK TO COVER WHEN READY: WALL FRAMING
AND SOUTH FACE 1ST LAYER 5/8" TYPE X GWB; NORTH FACE 1ST
LAYER 5/8" TYPE X GWB; THEN OK TO TAPES, MUD AND
FIRE-STOP BOTH FACES AS NECESSARY

Partial Correction
2 Misc 1

**OK TO COVER WHEN READY FRAMING FOR WOOD PLATFORM
AND PONY WALLS AT NE CORNER WHERE TWO COATS OF
FLAME STOP INTUMESCENT PAINT (IM) HAVE BEEN APPLIED PER
MFGR INSTRUCTIONS.**

Comments: