

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,  
MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Passed	Monday, March 13, 2017

**Comments: NO ISSUES FOUND ON MATERIAL & WORKMANSHIP ON UNDER-SLAB ELECTRICAL  
CONDUIT -- TWO RUNS AT NW & SW CORNERS OF BLDG "A" WEST. OK TO COVER WHEN READY.**