

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162996, Building Permit - Residential

Address: 2142 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822144 SW TIMBERTRACE LN, LEES
SUMMIT, MO 640822146 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822140 SW
TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Monday, March 13, 2017

Corrective Action Required

1	Misc 1	- complete electrcial switch box at hall bath at 2142
		2140-firestop dbl wall with solid material
		-block joist at bearing over i beam.
		ok to insulate

Electrical Service Inspection - Residential	Mark Harding	Passed	Monday, March 13, 2017
--	--------------	--------	------------------------

Rated Assembly Inspection	Mark Harding	Passed	Monday, March 13, 2017
----------------------------------	--------------	--------	------------------------

Erosion Control	Mark Harding	Failed	Monday, March 13, 2017
------------------------	--------------	--------	------------------------

Corrective Action Required

1	Misc 1	REQUESTED INSPECTIONS DENIED DUE TO LACK OF EROSION CONTROL AND DEBRIS IN THE STREET.
---	--------	---

Comments: