

Certificate of Occupancy

Permit #: PRCOM20162721
Address: 110 SW 3RD ST, LEES SUMMIT, MO 64063
Inspected On: Monday, March 13, 2017
Inspected By: John Borns

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - John Borns	Full C of O		Monday, March 13, 2017
Codes Commercial			

Comments: TWO MC ELECTRICAL CABLE RUNS AT REAR SPACE TO BE SECURED WITHIN 12" OF BOX. MICROWAVE RECEPTACLE TO BE SINGLE IF NOT GFCI-PROTECTED.