

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162603, Building Permit - Residential
Address: 308 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mike Copeland	Passed	Monday, March 13, 2017
Electrical Service Inspection - Residential	Mike Copeland	Passed	Monday, March 13, 2017
All Rough Inspection - Residential	Mike Copeland	Failed	Monday, March 13, 2017

Corrective Action Required

1	Misc 1	-NAIL ALL CHORDS OF THE GIRDERS PER PLANS -H-CLIP BOTH SIDES OF THE GIRDER TRUSSES -B-VENT CLEARANCE TO COMBUSTABLES IN THE GARAGE. -NAIL ALL CORNER STUDS 12" O.C. -UNCOVER FRAMING FOR COVERED PORCH
---	--------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Gas Piping Inspection - Residential	Mike Copeland	Passed	Monday, March 13, 2017
--------------------------------------------	---------------	--------	------------------------

Comments: