

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20162575, Building Permit - Residential  
Address: 304 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:  | Inspector:    | Outcome: | Date:                  |
|--|---------------|----------|------------------------|
| <b>Electrical Service<br/>Inspection - Residential</b> | Mike Copeland | Passed   | Monday, March 13, 2017 |

|   |               |        |                        |
|---|---------------|--------|------------------------|
| <b>All Rough Inspection -<br/>Residential</b> | Mike Copeland | Failed | Monday, March 13, 2017 |
|---|---------------|--------|------------------------|

Corrective Action Required

|   |        |  |
|---|--------|--|
| 1 | Misc 1 | -INSTALL TRUSS HANGERS PER THE LAYOUT, SEVERAL MISSING<br>-FIREBLOCK REAR WALL BASEMENT<br>-NAIL CORNER STUDS<br>-B-VENT CLEARANCE IN GARAGE<br>-INSTALL ANCHOR BOLTS 2 PER PLATE SECTION, MINIMUM 1<br>WITHIN 6" OF PLATE BREAK<br>-H CLIP BOTH SIDES OF GIRDER TRUSSES |
|---|--------|--|

|   |               |        |                        |
|---|---------------|--------|------------------------|
| <b>Gas Service Inspection -<br/>Residential</b> | Mike Copeland | Failed | Monday, March 13, 2017 |
|---|---------------|--------|------------------------|

**Comments:**