

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, March 14, 2017
Partial Correction 1 Misc 1		RATED WEST AND EAST STAIRWELLS: OK TO TAPE, MUD AND FIRE-STOP UNIT FACE AND STAIRWELL FACE FULL HEIGHT BOTH STAIRS	
Partial Correction 2 Misc 1		OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X GWB AT 1ST FLOOR CEILINGS AND WALLS AT: 106; 108; 113; 114; 115; 109; 111 INCLUDING EAST WALL ABOVE CEILING; MAIN CORRIDOR; 102-4 116-7	
Partial Correction 3 Misc 1		OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X GWB AT 2ND FLOOR CEILINGS AND WALLS AT: CORRIDOR; 206; 208; 213; 214; 215; 209; 211; 202-4 216-7	
Partial Correction 4 Misc 1		OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X GWB AT 3RD FLOOR CEILINGS AND WALLS AT: CORRIDOR; 306; 308; 309; 311; 313; 314; 315; 302-4 316-7	

Comments: