

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162931, Building Permit - Commercial
Address: 1748 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Tuesday, March 14, 2017

Corrective Action Required

1	Misc 1	II-B OCCUPANCY REQUIRES IN-WALL BLOCKING TO BE STAMPED "FIRE-TREATED"
---	--------	--

Comments: DO NOT COVER WALLS.