

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20161027, Public Works Infrastructure Permit - Commercial

TWIN LAKES INSURANCE

Address: 2641 NE MCBAIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Water Line - Construction Taps Removed	Tom Chandler	Partial	Tuesday, March 14, 2017

Informational

- 1 Tom Chandler 02/17/2017 1:17 PM Installing water line going into building and water line going to private hydrant.  
Tom Chandler 02/28/2017 4:15 PM Water department performed test shutdown and located valves. Will need to do shutdown to cut in a tee for a fire line and backflow valve and vault.  
Tom Chandler 03/14/2017 3:13 PM Water department will be out in the morning to help locate water line. Will do shut down in the afternoon to allow for cut-in tee to be installed.

Comments: