

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, March 15, 2017

Partial Correction
1 Misc 1

AT ELEVATOR EQUIPMENT ROOM A150 OK TO APPLY 1ST LAYER 5/8" TYPE X GWB AT WEST WALL, 2 LAYERS AT CONNECTION WITH INTERSECTING WALL; 2ND LAYER 5/8" TYPE X GWB AT WEST WALL; FRAMING + ONE LAYER 1" LINER BOARD AT CEILING; SOUTH WALL OK TO COVER SOUTH FACE OF SOUTH WALL WITH 5/8" TYPE X; OK TO COVER SOUTH FACE OF SOUTH WALL WITH 2ND LAYER 5/8" TYPE X; OK TO INSTALL 1ST LAYER 5/8" TYPE X GWB AT CEILING;

Partial Correction
2 Misc 1

ELEVATOR SHAFT -- OK TO COVER WHEN READY: FRAMING + LINER BOARD FULL HEIGHT NORTH, EAST, SOUTH WALLS; EAST WALL 2ND FLOOR 1ST LAYER 5/8" TYPE X; 1ST FLOOR S WALL OK TO HANG 2ND LAYER 5/8" TYPE X GWB; 1ST FLOOR N WALL OK TO HANG BOTH LAYERS 5/8" TYPE X GWB; 2ND FLOOR OK FOR 2ND LAYER 5/8" TYPE X AT N,E,S WALLS;

Partial Correction
3 Misc 1

SEPARATION WALL ON (6): PENETRATIONS OF LINER BOARD FIRE-STOPPED; OK TO HANG 5/8" TYPE X GWB BOTH FACES;

Partial Correction
4 Misc 1

PARAPET BETWEEN AC SECTIONS AND BD, MINERAL WOOL AND FIRE PROOFING BETWEEN SHAFT WALLS APPROVED.

In-wall Inspection	John Borns	Partial	Wednesday, March 15, 2017
---------------------------	------------	---------	---------------------------

Partial Correction
2 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING

+ IN-WALL SYSTEMS AT FOLLOWING 2ND FLOOR LOCATIONS:
A218; C271; AREA "A"; AREA "C" N OF STAIR; **C202; C203; C206;
C207;**

BETWEEN COMMONS A-C EXCEPT 202,3,6,9,18.

Partial Correction
1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING
+ IN-WALL SYSTEMS AT FOLLOWING 1ST FLOOR LOCATIONS: EAST
WALL OF ELECT 3-161; OK TO 4' TOP-OUT WALLS; AREA "A"; AREA
"C" COMPLETE EXCEPT C160; B153; D161; B209; B258A;

Partial Correction
3 Misc 1

**OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL
FRAMING + IN-WALL SYSTEMS AT FOLLOWING MEZZANINE
LOCATIONS: 301 WEST WALL;**

Comments: