

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20161624, Building Permit - Residential
Address: 3349 SW JESSIE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mike Copeland	Not Ready	Wednesday, March 15, 2017

Corrective Action Required

1 Misc 1

GROUND TO COPPER WATER LINE

SPRAYING PAINT INSIDE, CANNOT ACCESS TO INSPECT

Comments: