

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161750, Building Permit - Commercial
Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Thursday, March 16, 2017

Partial Correction
1 Misc 1

OK TO COVER WHEN READY UNDERGROUND CONDUIT (TWO 4" & TWO 1-1/4" PVC + ONE 2" DURA-LINE) FROM BUILDING ENTRY AT EAST CENTER NORTH TO NEAR BOX LOCATION AT DRIVEWAY

Partial Correction
2 Misc 1

NO MATERIAL OR WORKMANSHIP ISSUES FOUND ON SECONDARY ELECTRICAL SERVICE CONDUITS TRENCHED AND LAID FROM TRANSFORMER LOCATIONS TO BUILDING ENTRIES AT NORTH AND SOUTH ENDS OF BUILDING

Comments: