

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161758, Building Permit - Commercial  
Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Thursday, March 16, 2017

Partial Correction

1          Misc 1

DATAComm CONDUIT NETWORK TO BUILDINGS:  
QUAZITE BOX (A) SET IN PLACE  
TWO 4" + TWO 1-1/4" PVC + 2" ROLLPIPE...  
FROM QUAZITE BOX (A) TO BLDG #1; TO BLDG #2; TO CLUBHOUSE; NORTH TO 50' N OF FIRE HYDRANT; N TO Q-BOX LOCATION #3; N TO MARK (2.6); N/NW TO Q-BOX LOCATION #2); BETWEEN BLDGS #3 & #4; BETWEEN BLDGS #5 & #7; OK TO COVER ALL DATAComm TRENCHED CONDUIT TO CLUBHOUSE & BLDGS #1 THRU #7; SOME BOXES YET TO BE SET

Partial Correction

2          Misc 1

**NO MATERIAL OR WORKMANSHIP ISSUES FOUND ON SECONDARY ELECTRICAL SERVICE CONDUITS TRENCHED AND LAID FROM TRANSFORMER LOCATION TO BUILDING ENTRY AT NORTH END OF BLDG**

**Comments:**