

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161756, Building Permit - Commercial  
Address: 795 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|   |            |          |                          |
|---|------------|----------|--------------------------|
| Inspection:   | Inspector: | Outcome: | Date:                    |
| <b>Underground Electrical Inspection - Commercial</b> | John Borns | Partial  | Thursday, March 16, 2017 |

Partial Correction  
1 Misc 1

**NO MATERIAL OR WORKMANSHIP ISSUES FOUND ON  
SECONDARY ELECTRICAL SERVICE CONDUITS TRENCHED AND  
LAID FROM TRANSFORMER LOCATIONS TO BUILDING ENTRIES  
AT NORTH & SOUTH ENDS OF BLDG.**

**Comments:**