

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162048, Building Permit - Commercial
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	John Borns	Partial	Friday, March 17, 2017
Underslab Plumbing Inspection - Commercial	John Borns	Passed	Friday, March 17, 2017

Comments: CHANNEL FLOOR SLAB CUTS HAVE BEEN DRY-DRIVEN DOWELED AT WIDER AREAS. AT NARROW CUTS LONGITUDINAL BARS HAVE BEEN PLACED BUT ARE NOT CHAIRED-UP. BAR DEPTH IN SLAB WILL BE UNKNOWN.