

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20170699, Building Permit - Commercial
Address: 232 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Passed	Friday, March 17, 2017

Comments: NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CHANNELED INTO EXISTING FLOOR: TWO 3/4" PVC CONDUITS WITH THREE PVC FLOOR BOXES. OK TO COVER WHEN READY.