

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162583, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Friday, March 17, 2017

Partial Correction
1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING FOR SOFFITS ABOVE DOORS AT TWO PREP ROOMS; SOFFIT AT 1C115/116 BLOOD DRAW WAITING AFTER TWO ABANDONED STUDS ARE REMOVED;

Partial Correction
2 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 1C216; 1C133; C137; [1D25]; 1C217; 1C218A; 1C219; 1C221; 1C223; 1C218 INCLUDING EAST 1/2; 1D24; 1D26 AFTER RATED WALL STICKERS ARE ADHERED TO WALL RATHER THAN TO M/E/P COMPONENTS; 1C117-1C120; 1C101; 1D25; 1D26; 1C1122; 1C123; FACIA ONLY AT SOFFIT IN 1C116; PARTIAL FOR MODIFICATIONS AT IR READ ROOM 116; 1C197 AFTER ELECTRICAL BOXES ARE SECURED AND CLOSED; 1C115;1C116; **ABOVE-CEILING MODIFICATIONS AT MAIN WAITING ROOMS EXPANSION SPACE TO BE COMPLETED DURING OFF-HOURS AND PUT INTO USE IMMEDIATELY OK TO COVER WHEN READY;**

Comments: