

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162363, Building Permit - Commercial  
Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Partial	Monday, March 20, 2017

Partial Correction  
1 Misc 1

OK TO POUR WHEN READY PERIMETER FOOTING & INTEGRAL COLUMN FOOTINGS AT N, E, & S. NO UFER JUMPERS INSTALLED IN THESE SECTIONS.

12/30-OK THE ELEVATOR SLAB

Partial Correction  
2 Misc 1

OK TO POUR POST-TENSIONED FLOOR SLAB SYSTEM AS APPROVED BY SPECIAL INSPECTOR.

Partial Correction  
3 Misc 1

**OK TO POUR WHEN READY RETAINING WALL FOOTINGS AT SW & NW**

**Comments:**