

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162365, Building Permit - Commercial
Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	John Borns	Partial	Monday, March 20, 2017

Partial Correction
1 Misc 1

ELEVATOR PIT WALLS: EAST WALL HANGS OVER EDGE OF SLAB;
EDGE OF SLAB HAS BEEN DOWELED. CONDITION ALLOWED THIS
INSTANCE ONLY AS EXCEPTION TO DRAWINGS.

Partial Correction
2 Misc 1

OK TO POUR POST-TENSIONED BUILDING FLOOR SLAB SYSTEM AS
APPROVED BY SPECIAL INSPECTOR. ENSURE UFER GROUND
LEADS REMAIN EXTENDED OUTSIDE POUR.

Partial Correction
3 Misc 1

OK TO POUR POST-TENSIONED GARAGE FLOOR SLAB SYSTEM AS
APPROVED BY SPECIAL INSPECTOR.

Partial Correction
4 Misc 1

OK TO POUR WHEN READY STUB WALLS AT N & S ENDS

Comments: