

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161058, Building Permit - Commercial
Address: 1200 SE HAMBLEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Mike Copeland	Partial	Tuesday, March 21, 2017

Partial Correction
1 Misc 1

GROUND RING: GROUND RING AND RODS ASSOCIATED WITH THE GROUND RINGS AT THE PERIMETER OF THE BUILDING APPROVED.

LIGHTNING PROTECTION FOR COVERED PARKING APPROVED.
CONDUITES FOR FLAG POLE AND MONUMENT SIGN APPROVED.

Comments: