

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20163096, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Tuesday, March 21, 2017

Partial Correction

1          Misc 1

OK TO COVER WHEN READY BURIED CONDUIT FOR SITE ELECTRICAL SYSTEM: TWO 1" PVC CONDUITS ACROSS NORTH DRIVEWAY APRON + TWO 1-1/2" PVC CONDUITS TO 70' WEST INTO PARKING LOT, EAST END OF WHICH IS TO BE EXTENDED/BORED EAST TO REAR OF MAIN BUILDING; **FROM EXISTING QUAZITE BOX AT PRINT MARK (30) TO NEW Q-BOX AT (31) ; FROM Q-BOX AT (32) TO EXISTING WALL-MOUNTED J.B. AT (33);**

Partial Correction

2          Misc 1

OK TO POUR WHEN READY LIGHT POLE BASES: ALL EXCEPT A,15

Partial Correction

3          Misc 1

OK TO COVER WHEN READY BURIED CONDUIT TO LIGHT POLE LOCATIONS: FROM L.P. B,8 TO B,9 TO B,10; FROM B,10 TO A,12 TO A,13;

**Comments:**