

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162366, Building Permit - Commercial  
Address: 825 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Thursday, March 23, 2017

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY PVC CONDUIT TRENCHED BETWEEN APARTMENT BUILDING AND DETACHED GARAGES: ONE 1-1/4" FROM BUILDING TO BUILDING + ONE 3/4" FROM GARAGE TO MIDWAY BETWEEN BUILDINGS STUBBED UP FOR FUTURE EXTENSION FOR SITE LIGHTING

**Comments:**