

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Friday, March 24, 2017

Partial Correction
1 Misc 1

NO ISSUES FOUND ON VISUAL INSPECTION OF 3" GAS PIPE FROM BUILDING ENTRY TO MEZZANINE. P.C. PRESSURE-TESTED 3" LINE; CUMULATIVE PRESSURE TEST OF 3" LINE + SUPPLY TO MED LABS C102 & C103; **VISUAL + PRESSURE TEST OF COMPLETE PIPING SYSTEM EXCEPT AT WATER HEATERS AND BOILERS**

In-wall Inspection	John Borns	Partial	Friday, March 24, 2017
---------------------------	------------	---------	------------------------

Partial Correction
1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 2ND FLOOR LOCATIONS: A218; C271; AREA "A"; AREA "C" N OF STAIR; C202; C203; C206; C207; B209; B258A; C218; C205; 202; 203;

BETWEEN COMMONS A-C EXCEPT 202,3,6,9,18.

Partial Correction
2 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 1ST FLOOR LOCATIONS: EAST WALL OF ELECT 3-161; OK TO 4' TOP-OUT WALLS; AREA "A"; AREA "C" COMPLETE EXCEPT C160; B153; D161;

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 1ST FLOOR LOCATIONS: EAST WALL OF ELECT 3-161; OK TO 4' TOP-OUT WALLS; AREA "A"; AREA "C" COMPLETE EXCEPT C160; B153; D161; B209; B258A;

Partial Correction
3 Misc 1

AREA "D": D150/151/152 NORTH & WEST WALLS; 150A; 151A;
152A; 153; 154; 155; 159; 160; 162; **D156; D157;**

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING
+ IN-WALL SYSTEMS AT FOLLOWING MEZZANINE LOCATIONS:
301 WEST WALL;

Comments: