

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162628, Building Permit - Commercial  
Address: 820 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Monday, March 27, 2017
Partial Correction 1          Misc 1		OK TO COVER WHEN READY GWB CEILING / SOFFIT FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: <b>SOFFIT/BULKHEAD AT SALES AREA W/SW;</b>	
<b>In-wall Inspection</b>	John Borns	Partial	Monday, March 27, 2017
Partial Correction 1          Misc 1		OK TO COVER WHEN READY EXTERIOR INSULATED WALLS AT SOUTH AND EAST;  <b>INTERIOR LIGHT-GAUGE STEEL-FRAMED WALLS AND IN-WALL SYSTEMS INCLUDING AT MEZZANINE AND AT TOILET ROOM EXCEPT EAST WALL</b>  -THREE WALL SECTIONS AT SIDES OF OVERHEAD DOORS; MURAL WALL SECTION	
Corrective Action Required 2          Misc 1		<b>BOCA PLATES REQUIRED TO PROTECT PVC PIPING AT BOTTOM TRACK AT TOILET EAST WALL</b>	

**Comments:**