



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20161178	Date:	March 27, 2017
Project Title:	JOHN KNOX VILLAGE - MEADOWS	Applicant:	TYCO Simplex Grinnell 11019 Strang Line Road Lenexa, Kansas 66215
Location:	1800 NW OBRIEN RD, LEES SUMMIT, MO 64081		
Type of Work:			
Occupancy Group:	A-2		
Description:	COMMONS BUILDING		
Construction Type:	Type VA (1 hour)		
Map Page:	194D		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Rejected

1. Original fire alarm plans (not alterations) shall come bearing a PE stamp.
2. Check all stairways throughout all buildings all floors to assure there are no strobe notification devices located within the stairways.
3. Check all corridor fire doors throughout all buildings and all floors to assure there is a smoke detector on each side of the doors.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2016 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Acceptance testing of the system will be required prior to final occupancy inspection. To schedule testing contact the fire department at 816-969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.