



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20162811	Date:	March 27, 2017
Project Title:	BIG WHISKEY'S	Applicant:	
Location:	860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086	ABSOLUTE FIRE INC	
Type of Work:		13906 CENTURY LN	
Occupancy Group:	A-2	GRANDVIEW, MO 64030	
Description:	TENANT FINISH FOR FULL SERVICE RESTAURANT	Primary:	(816) 737-9991
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Field tests and acceptance testing of the system will be required prior to the final occupancy inspection. To schedule testing contact the fire department at 816-969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.