

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20162977, Building Permit - Residential

Address: 2132 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822134 SW TIMBERTRACE LN, LEES  
SUMMIT, MO 640822136 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822130 SW  
TIMBERTRACE LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mike Copeland	Not Ready	Monday, March 27, 2017

### Corrective Action Required

1      Misc 1

-braced wall straping needs to be installed correctly, not loose.  
2130 east unit 2nd floor  
-2136 seal ridge from unit east.

units locked at 8:30am  
all trash needs to be picked up at rear of lots, north tree line asap.  
recall  
ok to insulate  
DENIED DUE TO TRASH AND DEBRIS

**Comments:**