

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162628, Building Permit - Commercial
Address: 820 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Monday, March 27, 2017
Partial Correction 1 Misc 1		OK TO COVER WHEN READY GWB CEILING / SOFFIT FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: SOFFIT/BULKHEAD AT SALES AREA W/SW;	
In-wall Inspection	John Borns	Partial	Monday, March 27, 2017
Partial Correction 1 Misc 1		OK TO COVER WHEN READY EXTERIOR INSULATED WALLS AT SOUTH AND EAST; INTERIOR LIGHT GAUGE STEEL FRAMED WALLS AND IN-WALL SYSTEMS INCLUDING AT MEZZANINE AND AT TOILET ROOM EXCEPT EAST WALL -THREE WALL SECTIONS AT SIDES OF OVERHEAD DOORS; MURAL WALL SECTION	
Corrective Action Required 2 Misc 1		BOCA PLATES REQUIRED TO PROTECT PVC PIPING AT BOTTOM TRACK AT TOILET EAST WALL	
In-wall Inspection	John Borns	Passed	Monday, March 27, 2017

Comments:

