

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162979, Building Permit - Residential

Address: 2122 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822124 SW TIMBERTRACE LN, LEES
SUMMIT, MO 640822126 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822120 SW
TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Tuesday, March 28, 2017

Corrective Action Required

1	Misc 1	-FAR EASH AND WEST UNIT, SUPPORT FRONT BED HIPS AND VALLY RAFTERS -INSTALL BRACED WALL STRAPS AS REQUIRED -INSTALL CRIPPLE STUDS WITH FULL BEARING -INSTALL ANCHOR BOLTS 2 PER PLATE OKAY TO INSULATE
---	--------	---

Electrical Service Inspection - Residential	Mike Copeland	Failed	Tuesday, March 28, 2017
--	---------------	--------	-------------------------

Corrective Action Required

1	Misc 1	125 FUSES INSTALLED AND THE PANEL IS LISTED FOR 400 AMPS.
---	--------	---

Rated Assembly Inspection	Mike Copeland	Passed	Tuesday, March 28, 2017
----------------------------------	---------------	--------	-------------------------

Comments: