



**LEE'S SUMMIT**  
**MISSOURI**



---

**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20170233	Date:	March 29, 2017
Project Title:	AMAZING LASH STUDIO	Applicant:	
Location:	930 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086	<NO CONTACT NAME AVAILABLE>	<NO CONTACT INFORMATION AVAILABLE>
Type of Work:			
Occupancy Group:			
Description:	TENANT FINISH FOR EYELASH EXTENSION SERVICE	KANSAS CITY FIRE AND SECURITY LLC	
Construction Type:	Type IIB (Unprotected)	901 E LOULA ST	
Map Page:	195A	OLATHE, KS 66061	
		Primary: (913) 780-5237	

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

**1. ACTION REQUIRED:**

Acceptance testing of the alarm notification and activation devices will be required prior to the final occupancy inspection. To schedule testing contact the fire department at 816-969-1300.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**