

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162603, Building Permit - Residential
Address: 308 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, March 29, 2017

Corrective Action Required

1 Misc 1

-NAIL ALL CHORDS OF THE GIRDERS PER PLANS
**2ND FL GIRDERS NOT NAILED PROPERLY; COMPLETE
INSTALLING THE HANGER THAT CONNECT GIRDER TO GIRDER
NEAR DUCT CHASE

-H-CLIP BOTH SIDES OF THE GIRDER TRUSSES
**2ND FL

Comments: