



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

March 29, 2017

SCHARHAG ARCHITECTS
310 ARMOR RD, #22
NORTH KANSAS CITY, MO 64116

Permit No: PRCOM20170850
Project Title: ABSOLUTE HAIR & NAILS
Project Address: 236 NW OLDHAM PKWY, LEES SUMMIT, MO 64081
Parcel Number: 62140031600000000
Location: SUMMIT SHOPPING CENTER LOT 1
Type of Work: NEW TENANT FINISH
Occupancy Group:
Description: TENANT FINISH FOR HAIR AND NAIL SALON

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:

Provide a minimum of one 2A-10BC (5 pound) fire extinguisher. to be mounted on a normal path of travel close to an exit. (verified at inspection)

2. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:

Post the numeric address of 236 on the exterior of the front and back doors in a contrasting color to the background where posted. The address shall be readable from the roadway. (verified at inspection)

3. ACTION REQUIRED:

NO KEYED LOCKS ON THE EGRESS SIDE OF THE FRONT AND BACK DOORS.

[B] 1008.1.9 Door operations.

Except as specifically permitted by this section egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

[B] 1008.1.9.4 Bolt locks.

Manually operated flush bolts or surface bolts are not permitted.

Exceptions:

1. On doors not required for egress in individual dwelling units or sleeping units.
2. Where a pair of doors serves a storage or equipment room, manually operated edge- or surface-mounted bolts are permitted on the inactive leaf.
3. Where a pair of doors serves an occupant load of less than 50 persons in a Group B, F or S occupancy, manually operated edge- or surface-mounted bolts are permitted on the inactive leaf. The inactive leaf shall contain no doorknobs, panic bars or similar operating hardware.
4. Where a pair of doors serves a Group B, F or S occupancy, manually operated edge- or surface-mounted bolts are permitted on the inactive leaf provided such inactive leaf is not needed to meet egress width requirements and the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. The inactive leaf shall contain no doorknobs, panic bars or similar operating hardware.
5. Where a pair of doors serves patient care rooms in Group I-2 occupancies, self-latching edge- or surface-mounted bolts are permitted on the inactive leaf provided that the inactive leaf is not needed to meet egress width requirements and the inactive leaf contains no doorknobs, panic bars or similar operating hardware.

[B] 1008.1.9.5 Unlatching.

The unlatching of any door or leaf shall not require more than one operation.

[B] 1008.1.9.1 Hardware.

Door handles, pulls, latches, locks and other operating devices on doors required to be accessible by Chapter 11 of the International Building Code shall not require tight grasping, tight pinching or twisting of the wrist to operate.
(verified at inspection)

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.