



## FIRE DEPARTMENT

### PLAN REVIEW CONDITIONS

March 30, 2017

HOKE JAKE  
PO BOX 388  
LEES SUMMIT, MO 64063

Permit No: PRCOM20170889  
Project Title: HYVEE  
Project Address: 301 SW WARD RD, LEES SUMMIT, MO 64081  
Parcel Number: 62610010100000000  
Location: PATTERSON OIL LOT 1---LOT 1  
Type of Work: ALTERATION COMMERCIAL  
Occupancy Group:  
Description: HYVEE DONUT FRYER AND HOOD

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Pending**

**Fire Plan Review**

**Reviewed By: Joe Dir**

**Approved with Conditions**

**1. ACTION REQUIRED:**

Suppression system for the Type-1 hood shall be wired in the the buildings fire alarm system.

2. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

**ACTION REQUIRED:**

Acceptance testing of the type-1 hood suppression system shall be required prior to use of the hood and fryer. To schedule a test contact the fire department at 816-969-1300.

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***