



## FIRE DEPARTMENT

### PLAN REVIEW CONDITIONS

March 30, 2017

GUY GRONBERG ARCHITECTS  
113 SE 3RD ST  
LEES SUMMIT, MO 64063

Permit No: PRCOM20170898  
Project Title: GOING POSTAL  
Project Address: 196 NW OLDHAM PKWY, Unit:A, LEES SUMMIT, MO 64081  
Parcel Number:  
Location:  
Type of Work: CHANGE OF TENANT  
Occupancy Group:  
Description: TENANT FINISH FOR SHIPPING/RECEIVING STORE

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Pending**

**Fire Plan Review**

**Reviewed By: Joe Dir**

**Approved with Conditions**

**1. ACTION REQUIRED:**

No keyed locks on the egress side of an exit

[B] 1008.1.9 Door operations.

Except as specifically permitted by this section egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

[B] 1008.1.9.1 Hardware.

Door handles, pulls, latches, locks and other operating devices on doors required to be accessible by Chapter 11 of the International Building Code shall not require tight grasping, tight pinching or twisting of the wrist to operate. (verified at inspection)

2. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

**ACTION REQUIRED:**

Post the numeric address on the exterior of the front and rear doors in a color that is contrasting where posted. (verified at inspection)

3. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

**ACTION REQUIRED:**

Provide at a minimum one 2A-10BC fire extinguisher to be mounted on a normal path of travel close to an exit. (verified at inspection)

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***