



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20162931	Date:	March 30, 2017
Project Title:	MASSAGE ENVY #1335	Applicant:	
Location:	1748 NW CHIPMAN RD, LEES SUMMIT, MO 64081	TED SYSTEMS LLC 12314 W 62ND TER SHAWNEE, KS 66216-1861	
Type of Work:			
Occupancy Group:	B	Primary:	(913) 677-5771
Description:	TENANT FINISH FOR MASSAGE THERAPY CLINIC		
Construction Type:	Type IIB (Unprotected)		
Map Page:	194D		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Acceptance testing of the fire alarm system notification and activation devices will be required prior to the final occupancy inspection. to schedule a test contact the fire department ant 816-969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.