

## **CODES ADMINISTRATION**

## **Temporary Certificate of Occupancy**

Permit #: PRRES20162248

**Address:** 1353 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

**Inspected On:** Friday, March 31, 2017

**Inspected By:** Khanh Nguyen

**Expiration Date:** 5/1/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

**Occupancy Inspection -**Khanh Nguyen Temporary C of O Friday, March 31, 2017

**Codes Residential** 

Corrective Action Required:

-THE STAIR WINDER TREADS SHALL HAVE MIN. 6" OF DEPTH AT THE 1 Misc 1

NARROWEST END. BOTH ADJACENT WINDER TREADS MUST HAVE

**CONSISTENT DEPTH WITHIN 3/8"** 

\*\*CODE REQUIRES THAT EVERY TREAD MUST HAVE A NOSING