

**CODES ADMINISTRATION**

**PLAN REVIEW CONDITIONS**

March 31, 2017

GUY GRONBERG ARCHITECTS  
113 SE 3RD ST  
LEES SUMMIT, MO 64063

Permit No: PRCOM20170898  
Project Title: GOING POSTAL  
Project Address: 196 NW OLDHAM PKWY, Unit:A, LEES SUMMIT, MO 64081  
Parcel Number: 62140031600000000  
Location: SUMMIT SHOPPING CENTER LOT 1  
Type of Work: CHANGE OF TENANT  
Occupancy Group:  
Description: TENANT FINISH FOR SHIPPING/RECEIVING STORE

***Revisions Required***

***One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.***

Planning and Codes Administration (816) 969-1200

Fire Department (816) 969-1300

**Licensed Contractors**

**Reviewed By: Joe Frogge**

**Rejected**

1. Lee's Summit Code of Ordinance, Section7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

2. Lee's Summit Code of Ordinance, Section7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Approved with Conditions**

1. The project cost, which is used to establish the permit fee, has not been provided.

Action required: Comment is for informational purposes.

**Fire Plan Review**

**Reviewed By: Joe Dir**

**Approved with Conditions**

---

**CODES ADMINISTRATION**

1. ACTION REQUIRED:

No keyed locks on the egress side of an exit

[B] 1008.1.9 Door operations.

Except as specifically permitted by this section egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

[B] 1008.1.9.1 Hardware.

Door handles, pulls, latches, locks and other operating devices on doors required to be accessible by Chapter 11 of the International Building Code shall not require tight grasping, tight pinching or twisting of the wrist to operate.

(verified at inspection)

2. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:

Post the numeric address on the exterior of the front and rear doors in a color that is contrasting where posted.

(verified at inspection)

3. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:

Provide at a minimum one 2A-10BC fire extinguisher to be mounted on a normal path of travel close to an exit. (verified at inspection)

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***