

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20163072, Building Permit - Residential  
Address: 510 NW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Residential</b>	John Borns	Passed	Friday, March 31, 2017

**Comments: HOUSE AS RENOVATED OK FOR USE & OCCUPANCY AFTER:**

- INSTALL ANTI-TIP DEVICE AT KITCHEN RANGE
- SECURE TOP AND BOTTOM PLATES OF STEEL POSTS AT BASEMENT TO SLAB AND CARRIED BEAM
- CLAMP LIQUID-TIGHT ELECTRICAL WHIP FOR A/C WITHIN 12" OF ENTRY TO DISCONNECT BOX