

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20160277, Building Permit - Commercial  
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Friday, March 31, 2017
Partial Correction 1 Misc 1		AREA SEPARATION WALL ON (7): ABOVE ROOF EAST FACE -- DEFLECTION CLIP SCREWS VERIFIED	
Partial Correction 2 Misc 1		LIGHT-GAUGE STEEL EXTERIOR WALL FRAMING SUBSTANTIALLY COMPLETE WITH NO ISSUES FOUND AT: NORTH ELEVATION; WEST ELEVATION; SOUTH ELEVATION; EAST ELEVATION	
Partial Correction 3 Misc 1		NO ISSUES FOUND WITH INSTALLATION OF 16 GA. STEEL JOISTS FOR MECHANICAL DECKS ABOVE SPACES: D255; D258; D258A; D259; D260; D264	
Partial Correction 4 Misc 1		<b>OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING PER A/E RIVISION "METAL SHROUD LIGHT DETAIL" DTD 3/28/17: ON 1ST FLOOR AT 10.25/W-Y AND 10.75/J-L;</b>	

**Comments:**