

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Wednesday, April 05, 2017

Partial Correction
3 Misc 1

OK TO COVER WHEN READY GWB CEILING / SOFFIT FRAMING +
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES:
1ST FLOOR: MEETING ROOM PERIMETER & CLOSETS

Corrective Action Required
4 Misc 1

**ACT CEILING FRAMING & ABOVE-CEILING SYSTEMS: 4TH FLOOR
CORRIDOR: FIRE-STOP ALL PENETRATIONS OF WALLS AND
CEILING**

Comments: