

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162628, Building Permit - Commercial
Address: 820 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Failed	Wednesday, April 05, 2017

Corrective Action Required

1	Misc 1	SUPPORT GAS PIPE INSIDE BLDG AT INTERVALS PER IFGC, INCLUDING AT NORTH END
---	--------	--

Corrective Action Required

2	Misc 1	IFGC 404.8: METALLIC PIPING EXPOSED TO WEATHER MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS. SEE GAS PIPING AT METER AND ROOFTOP.
---	--------	--

Corrective Action Required

3	Misc 1	GAS PIPE SUPPORTS AT ROOFTOP NOT PER APPROVED DRAWING.
---	--------	--

Gas Service Inspection - Commercial	John Borns	Passed	Wednesday, April 05, 2017
--	------------	--------	---------------------------

Comments:

**GAS PIPING PRESSURE TEST HELD STEADY AT >= 10 PSI FOR >=10 MIN. RELEASE GAS SERVICE.
ADDRESS LABELING OF GAS SERVICE ENTRY PIPE: HANG PERMANENT TAG FROM LOAD SIDE ENTRY PIPE. FELT TIP MARKER NOT APPROVABLE.**