

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Thursday, April 06, 2017

Partial Correction
1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 2ND FLOOR LOCATIONS:
A218; C271; AREA "A"; AREA "C" N OF STAIR; C202; C203; C206;
C207; B209; B258A; C218; C205; 202; 203;

BETWEEN COMMONS A-C EXCEPT 202,3,6,9,18.

Partial Correction
2 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 1ST FLOOR LOCATIONS: EAST WALL OF ELECT 3-161; OK TO 4' TOP-OUT WALLS;

AREA "A" COMPLETE

AREA "B": B101 S,W,N WALLS; B102; 103; 104; 105; 106; 107; 108;
109; 110; 111; 152; 153; 153A; 153B; 154; 155; 156-161;

AREA "C" COMPLETE EXCEPT C160; B153; D161; B209; B258A;

AREA "D": D150/151/152 NORTH & WEST WALLS; 150A; 151A;
152A; 153; 154; 155; 159; 160; 162; D156; D157; D102; D103;
4-151A*; D154B*;

***: EAST WALL TO 12' AFF ONLY**

VERTICAL DEAD SPACE AT Q/4.8-5.4

Partial Correction
3 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING

+ IN-WALL SYSTEMS AT FOLLOWING MEZZANINE LOCATIONS:
301 WEST WALL;

**Rough Framing
Inspection -
Commercial**

John Borns

Partial

Thursday, April 06, 2017

Partial Correction

1 Misc 1

AREA SEPARATION WALL ON (7): ABOVE ROOF EAST FACE --
DEFLECTION CLIP SCREWS VERIFIED

Partial Correction

2 Misc 1

LIGHT-GAUGE STEEL EXTERIOR WALL FRAMING SUBSTANTIALLY
COMPLETE WITH NO ISSUES FOUND AT: NORTH ELEVATION;
WEST ELEVATION; SOUTH ELEVATION; EAST ELEVATION

Partial Correction

3 Misc 1

NO ISSUES FOUND WITH INSTALLATION OF 16 GA. STEEL JOISTS
FOR MECHANICAL DECKS ABOVE SPACES: D255; D258; D258A;
D259; D260; D264

Partial Correction

4 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING PER
A/E RIVISION "METAL SHROUD LIGHT DETAIL" DTD 3/28/17: ON
1ST FLOOR AT 10.25/W-Y AND 10.75/J-L; **10/I-K; 10.5/I-K;**

**Rated Assembly
Inspection**

John Borns

Partial

Thursday, April 06, 2017

Partial Correction

4 Misc 1

PARAPET BEWEEN AC SECTIONS AND BD, MINERAL WOOL AND
FIRE PROOFING BETWEEN SHAFT WALLS APPROVED.

Partial Correction

3 Misc 1

SEPARATION WALL ON (6):
INNER WYTHE: PENETRATIONS OF LINER BOARD FIRE-STOPPED;
OK TO HANG 5/8" TYPE X GWB BOTH FACES;

OUTER WYTHE: 1ST FLOOR FROM N TO R WEST FACE;

OUTER WYTHE: 2ND FLOOR FROM J TO N WEST FACE;

**WEST FINISH FACE: OK TO HANG 1ST LAYER TO 12' AFF FROM B
TO F**

**WEST FINISH FACE: OK TO HANG ONE LAYER FULL HEIGHT TO
2ND FLR ELEVATION FROM F TO N + FROM U TO 8' SHORT OF
BB;**

**EAST FINISH FACE OK TO HANG ONE LAYER FULL HEIGHT FROM
NEAR A TO BB**

Partial Correction

2 Misc 1

ELEVATOR SHAFT -- OK TO COVER WHEN READY: FRAMING + LINER BOARD FULL HEIGHT NORTH, EAST, SOUTH WALLS; EAST WALL 2ND FLOOR 1ST LAYER 5/8" TYPE X; 1ST FLOOR S WALL OK TO HANG 2ND LAYER 5/8" TYPE X GWB; 1ST FLOOR N WALL OK TO HANG BOTH LAYERS 5/8" TYPE X GWB; 2ND FLOOR OK FOR 2ND LAYER 5/8" TYPE X AT N,E,S WALLS;

Partial Correction

1 Misc 1

AT ELEVATOR EQUIPMENT ROOM A150 OK TO APPLY 1ST LAYER 5/8" TYPE X GWB AT WEST WALL, 2 LAYERS AT CONNECTION WITH INTERSECTING WALL; 2ND LAYER 5/8" TYPE X GWB AT WEST WALL; FRAMING + ONE LAYER 1" LINER BOARD AT CEILING; SOUTH WALL OK TO COVER SOUTH FACE OF SOUTH WALL WITH 5/8" TYPE X; OK TO COVER SOUTH FACE OF SOUTH WALL WITH 2ND LAYER 5/8" TYPE X; OK TO INSTALL 1ST LAYER 5/8" TYPE X GWB AT CEILING;

Comments: