



April 5, 2017

Dawn Bell
City of Lee's Summit
220 SE Green Street
Lee's Summit, MO 64063

RE:
Pad 5 At Summit Fair Retail Center
Dicks HM Permit #PRCOM 20170682
Chipman Road-Highway 50
Lee's Summit, Missouri
OA Project # 015-2698

Dear Ms. Bell:

Olsson Associates has reviewed the field changes made by Staco Electric to the electrical service for the above referenced project and electrical permit #PRCOM 20170682. The following changes are acceptable:

1. Driving the ground rods 6 feet apart from each other.
2. The existing owner transformer to be relocated was no longer needed for future use and was demolished and removed from the one line.
3. Utilizing (4) #1/0 aluminum service conductors instead of (4) #1 copper conductors for the service conductors.

Do not hesitate to call if you have any questions or comments.

Sincerely,

A handwritten signature in black ink, appearing to read 'Frank Egelhoff', is written over the printed name.

Frank Egelhoff
Olsson Associates