

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162811, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Passed	Friday, April 07, 2017

Gas Service Inspection - Commercial	John Borns	Passed	Friday, April 07, 2017
--	------------	--------	------------------------

Hood/Duct Inspection	John Borns	Partial	Friday, April 07, 2017
-----------------------------	------------	---------	------------------------

Partial Correction

1	Misc 1	IMC 506 COMMERCIAL KITCHEN GREASE DUCT FABRICATION & INSTALLATION: LIGHT TEST OF SEAM SHOP WELDS APPROVED; LIGHT TEST OF JOINT FIELD WELD APPROVED
---	--------	--

Comments: SOAP TEST ALL ACCESSIBLE JOINTS TO ENSURE NO GAS PIPE SEEPAGE. RELEASE TWO GAS SERVICES FOR 820W AND 820Y.