

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162366, Building Permit - Commercial
Address: 825 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	John Borns	Not Ready	Monday, April 10, 2017

Partial Correction

1	Misc	OK TO POUR POST-TENSIONED FLOOR SLAB SYSTEM AT WEST GARAGE (EAST AND CENTER GARAGE SLABS INSPECTED EARLIER) AS APPROVED BY SPECIAL INSPECTOR.
---	------	---

Partial Correction

2	Misc	STUB WALLS AT GARAGE EXTERIOR PERIMETER: STUB WALLS AT WEST GARAGE OK TO POUR WHEN READY;
---	------	---

**STUB WALLS AT CENTER GARAGE NOT APPROVED TO POUR.
RE-BAR IS COATED WITH FORM OIL.**

Partial Correction

3	Misc	STUB WALLS AT EAST AND WEST ENDS OF APARTMENT BUILDING OK TO POUR WHEN READY
---	------	--

Comments: