

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162811, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Partial	Monday, April 10, 2017

Partial Correction
1 Misc

IMC 506 COMMERCIAL KITCHEN GREASE DUCT FABRICATION & INSTALLATION: LIGHT TEST OF SEAM SHOP WELDS APPROVED; LIGHT TEST OF JOINT FIELD WELD APPROVED; **FIRE WRAP 1ST LAYER APPROVED TO COVER;**

Comments: