

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

April 10, 2017

THE WALDINGER CORPORATION
2601 BELL AVE
DES MOINES, IA 50321

Permit No: PRCOM20170889
Project Title: HYVEE
Project Address: 310 SW WARD RD, LEES SUMMIT, MO 64081
Parcel Number: 6261001010000000062610023400000000
Location: WAL-MART TRACT A
Type of Work: ALTERATION COMMERCIAL
Occupancy Group:
Description: HYVEE DONUT FRYER AND HOOD

**drawings are in plan review file

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. ACTION REQUIRED:

Suppression system for the Type-1 hood shall be wired in the the buildings fire alarm system.

2. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Acceptance testing of the type-1 hood suppression system shall be required prior to use of the hood and fryer. To schedule a test contact the fire department at 816-969-1300.

Licensed Contractors

Reviewed By: Joe Frogge

Approved

- ☒ Approved to issue per the listed conditions.
☐ Do not issue per the listed conditions.
☐ Approved to construct foundation only per the listed conditions.
☐ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

_____ Signature of Applicant	_____ Date
---------------------------------	---------------

_____ Print Applicant Name	_____ CompanyName
-------------------------------	----------------------

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.