

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Monday, April 10, 2017

Partial Correction

1 Misc

NO ISSUES FOUND ON DEEP UNDER-SLAB ELECTRICAL CONDUIT
MATERIAL & WORKMANSHIP: TEN 4" PVC SECONDARY
ELECTRICAL CONDUITS FROM [A109] SOUTHEAST TO F.2/12.5;
TEN 4" PVC SECONDARY ELECTRICAL CONDUIT ACROSS WIDTH
OF PARKING GARAGE NEAR (4);

Comments: